




I:\COMMON\CAD\TREATMENT\64 FILTERRAIN PROCESS TEMPLATES\FT-UG\DRIFTS FOR REVIEW\FTPDMH-UG - FILTERRA PEAK DIVERSION MANHOLE UNDERGROUND CONFIG DTL.DWG 12/12/2024 1:46 PM



PLAN VIEW
FTPDMH96-UG




PLAN VIEW
FTPDMH84-UG



PLAN VIEW
FTPDMH72-UG

ACCESS CASTINGS (REFER TO TABLE)
CONTRACTOR TO GROUT TO FINISHED
GRADE UNLESS CAST-IN FLUSH MOUNT




SECTION A-A
FTPDMH96 SHOWN


FTPDMH-UG CONFIGURATION (OPTIONS: GRATE INLET "-G")					
MANHOLE SIZE (Ø)	MEDIA AREA (SF)	PART NO.	AVAILABILITY	WEIR LENGTH	ACCESS CONFIGURATION IN / OUT / MEDIA
72"	13	FTPDMH72-UG	ALL	2'-10"	Ø24" / Ø12" / Ø30"
84"	17	FTPDMH84-UG	OR & WA ONLY	3'-3"	Ø24" / Ø24" / Ø30"
96"	23	FTPDMH96-UG	ALL	3'-9"	Ø24" / Ø24" / Ø30"

* IF REQUIRED BY LOCAL JURISDICTION, ON FTPDMH96 30" ACCESS MAY BE ALTERNATED WITH A 36"x36" HATCH FOR AN ADDITIONAL CHARGE.

ALTERNATE FTPDMH-G DETAILS



ROUND INLET GRATE



SQUARE INLET GRATE

The design and information shown on this drawing is provided as a service to the project owner, engineer and contractor by Contech Engineered Solutions LLC or one of its affiliated companies ("Contech"). Neither this drawing, nor any part thereof, may be used, reproduced or modified in any manner without the prior written consent of Contech. Failure to comply is done at the user's own risk and Contech expressly disclaims any liability or responsibility for such use. If discrepancies between the supplied information upon which the drawing is based and actual field conditions are encountered as site work progresses, these discrepancies must be reported to Contech immediately for re-evaluation of the design. Contech accepts no liability for designs based on missing, incomplete or inaccurate information supplied by others.



FOR PATENT INFORMATION, GO TO www.ContechES.com/IP



9100 Centre Pointe Dr., Suite 400, West Chester, OH 45069
800-338-1122 513-645-7000 513-645-7993 FAX

**FILTERRA PEAK DIVERSION MANHOLE -
UNDERGROUND (FTPDMH-UG)
CONFIGURATION DETAIL**