



I:\QUIKRETE\NET\CONTECH\COMMON\CAD\TREATMENT\54\FILTERRAIN PROCESS TEMPLATES\FT-UGD\RAFFTS FOR REVIEW\FT-UGD - FILTERRA OFFLINE UNDERGROUND CONFIG DTL.DWG - 12/14/2024 2:57 PM




ALTERNATIVE HATCH "-H" - ADDITIONAL CHARGE
(SEE NOTES BELOW)

SDR 35 OUTLET COUPLING CAST INTO PRECAST VAULT WALL (OUTLET PIPE LOCATION MAY VARY)

PLAN VIEW

ACCESS CASTING(S) DEPENDING ON VAULT SIZE AND DEPTH (REFER TO TABLE)



SECTION A-A
PIPE INLET (-P)

FT-UGD CONFIGURATION						
(OPTIONS: PIPE INLET "-P", ALTERNATE HATCH "-H")						
VAULT SIZE (L x W)	MEDIA AREA (SF)	PART NO.	AVAILABILITY	OUTLET PIPE DIA	MIN. # INLET PIPES (-P ONLY)	ACCESS CONFIG [†]
6 x 6	36	FT0606-UGD	ALL (EXCEPT CA, TX)	4" SDR 35	1	(1) Ø30"
10 x 6	60	FT1006-UGD	ALL (EXCEPT CA, TX)	6" SDR 35	2	(2) Ø30"
8 x 8	64	FT0808-UGD	CA, TX ONLY	6" SDR 35	2	(2) Ø30"
12 x 6	72	FT1206-UGD	ALL (EXCEPT TX)	6" SDR 35	2	(2) Ø30"
10 x 8	80	FT1008-UGD	CA, TX ONLY	6" SDR 35	2	(2) Ø30"
13 x 7	91	FT1307-UGD	ALL (EXCEPT CA, TX)	6" SDR 35	2	(2) Ø30"
12 x 8	96	FT1208-UGD	CA, TX ONLY	6" SDR 35	2	(2) Ø30"
14 x 8	112	FT1408-UGD	ALL	6" SDR 35	3	(3) Ø30"
16 x 8	128	FT1608-UGD	ALL (EXCEPT OR, WA)	6" SDR 35	3	(3) Ø30"
15 x 9	135	FT1509-UGD	OR, WA ONLY	6" SDR 35	3	(3) Ø30"
18 x 8	144	FT1808-UGD	CALL CONTECH	6" SDR 35	3	(3) Ø30"
20 x 8	160	FT2008-UGD	CALL CONTECH	6" SDR 35	4	(3) Ø30"
22 x 8	176	FT2208-UGD	CALL CONTECH	6" SDR 35	4	(3) Ø30"

INTERNAL PIPE CONFIGURATION MAY VARY BY VAULT SIZE
[†] IF REQUIRED BY LOCAL JURISDICTION, ON SIZES WITHOUT A HATCH AS STANDARD, ACCESS MAY BE ALTERNATED WITH A 36"x36" HATCH (48"x48" HATCH ON FT0808-UGD) FOR AN ADDITIONAL CHARGE.

9100 Centre Pointe Dr., Suite 400, West Chester, OH 45069
 800-338-1122 513-645-7000 513-645-7993 FAX

FILTERRA OFFLINE - UNDERGROUND DEEP (FT-UGD)

GREATER THAN 6'-6" RIM TO OUTLET CONFIGURATION DETAIL

